

TEST CERTIFICATE

Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested object: **wood/wood composite**

kind of material: (wood) WPC - Wood Plastic Composite
article description: Terrain
dimensions: 24 x 136 [mm] (t x w), l = variable
colour: Silver Maple
surface: embossed (wood-grain replication)
producer/supplier: TimberTech
894 Praire Avenue
Wilmington, Ohio 45177
U.S.A.

Applicant: TimberTech Ltd.
894 Prairie Ave.
Wilmington, Ohio 45177
U.S.A.

Certificate number: 61721302.001

Test date: 08.05.2013

Sampling: Sent by the customer to the research institute

Test method: **DIN 51130** (edition 10/2010)
"Testing of floor coverings; determination of the anti-slip property;
workrooms and fields of activities with slip danger; walking method
- ramp test"

Delivery has been effected in ready to test surface condition.
Elected joint width: 3-4 mm

Test result: Average total acceptance angle:
1st test direction (board longitudinally): **21,3°**
2nd test direction (board diagonally): **30,4°**

Assessment: **Classification group of anti-slip property: R11**

SÄUREFLIESNER-VEREINIGUNG E. V.
Institut für Wand- und Bodenbeläge
Managing Director



Dr.-Ing. Erich H. Nolting



Großburgwedel, 21.05.2013
Schu/ed

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The report is given for 5 years (starting from test date).
The publication and reproduction of this certificate is only allowed in unabridged form.

- Institut für Wand- und Bodenbeläge -
SÄUREFLIESNER-VEREINIGUNG E.V.

Im Langen Felde 4, 30938 Burgwedel · Telefon (05139) 99 82-0 · Telefax (05139) 99 82-40 · E-Mail: info@saeurefliesner.de

Anerkannte Prüf-, Zertifizierungs- und Überwachungsstelle d. DIBt und DIN CERTCO, Berlin · Notifizierte Prüfstelle der Kommission der EU, Brüssel, Kenn-Nr. 1212



TEST CERTIFICATE

of the slide-blocking property
in wet loaded barefoot areas of floor coverings

Tested material: **wood/wood composite**

kind of material: (wood) WPC - Wood Plastic Composite
article description: Terrain
dimensions: 24 x 136 [mm] (t x w), l = variable
colour: Silver Maple
surface: embossed (wood-grain replication)
producer/supplier: TimberTech
894 Praire Avenue
Wilmington, Ohio 45177
U.S.A.

Applicant: TimberTech Ltd.
894 Prairie Ave.
Wilmington, Ohio 45177
U.S.A.

Certificate number: 61721302.002

Test date: 02.05.2013

Sampling: Sent by the customer to the research institute

Test method: **DIN 51097**, ed. 11/92
"Testing of floor coverings; determination of the anti-slip properties;
wet-loaded barefoot areas; walking method - ramp test"
Side-blocking Floorings – List NB
"Requirements of the control-committee"
Delivery has been effected in ready to test surface condition.
Elected joint width: 3-4 mm

Test result: Average inclination angle:
1st test direction (board longitudinally): **33°**
2nd test direction (board diagonally): **34°**

Assessment: **Assessment group of anti-slip property: C**

SÄUREFLIESNER-VEREINIGUNG E. V.
Institut für Wand- und Bodenbeläge
Managing Director



Dr.-Ing. Erich H. Nolting



Großburgwedel, 21.05.2013
Schu/ed

This test-certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test-specimen. The report is given for 5 years (starting from test date).
The publication and reproduction of this report is only allowed in unabridged form.

– Institut für Wand- und Bodenbeläge –
SÄUREFLIESNER-VEREINIGUNG E.V.

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de

Anerkannte Prüf-, Zertifizierungs- und Überwachungsstelle d. DIBt und DIN CERTCO, Berlin · Notifizierte Prüfstelle der Kommission der EU, Brüssel, Kenn-Nr. 1212

